

SPECIFICATIONS

INSPECTION AND MAINTENANCE

FIRE EXTINGUISHERS AND KITCHEN HOOD SYSTEMS

The contractor shall furnish and deliver as required, services for inspection and maintenance of various types of fire extinguishers throughout Troup County. Inspection and service of several kitchen hood systems is also required.

- 1. Annual Inspection & Tagging.** The bidder shall provide an annual inspection of several types of fire extinguishers in accordance with the then-current National Fire Protection Association (NFPA) Standards. The inspections shall be coordinated with the individual Troup County departments. Each fire extinguisher shall be inspected, maintained and tagged to insure Troup County is in full compliance with all current Federal, State, County and Local standards, codes and ordinances.
- 2. Recharge of Extinguishers.** The bidder shall provide, as determined during annual inspection, recharge services as necessary for each type of fire extinguisher. The recharge of extinguishers shall be in accordance with the then-current NFPA Standards.
- 3. Hydro-testing.** The bidder shall provide as required, periodic hydro-testing for fire extinguishers. The hydro-testing shall be at the appropriate time interval determined by and in accordance with the then-current NFPA Standards.

When any of the above services are provided, a complete description of said services shall be provided which includes the type and size of fire extinguisher, the location and the type of service rendered.

Arrangements are to be made for a Troup County employee to be present at each site during inspections to insure that all extinguishers are inspected and tagged.

Any fire extinguisher removed from a location must be returned within 5 days.

The contractor, at all times during the contract, must be in full compliance with all Federal, State, County and Local standards, codes and ordinances pertaining to the specifications set forth above, as well as all then-current NFPA standards.

BID RESPONSE FORM

FIRE EXTINGUISHER AND KITCHEN HOOD SYSTEMS

INSPECTION AND MAINTENANCE

Provide pricing for each of the items below:

Fire Extinguisher Recharging and Purchasing

Size	ABC	BC	CO2	Purchase
2.5#				
5.0#				
10.0#				
15.0 #				
20.0#				

Semi Annual Kitchen Suppression System _____

Fire Extinguisher Hydro Testing – Low Pressure _____

High Pressure _____

Annual Inspection & Tag Fee _____

O-rings _____ Valve Stems _____ Pull Pins _____

Service Charge or Labor Fee _____

Company _____

Address _____

City, State, Zip _____

Telephone Number _____ Fax Number _____

Signature_____

Troup County Locations for Service

1. Troup County Government Services Center – 100 Ridley Avenue
2. Troup County Juvenile Court – 118 Ridley Avenue
3. Troup County Roads & Engineering – 100 Sam Walker Drive
4. Troup County Sheriff's Office & Jail – 130 Sam Walker Drive
5. Troup County Work Release – 2508 Hamilton Road
6. Troup County Public Defender's Office – 2508 Hamilton Road
7. Troup County Shop – 2520 Hamilton Road
8. Troup County Fire Dept. Training Ctr. – 2495 Hamilton Road
9. Troup County Fire Station One – 2471 Hamilton Road
10. Troup County Fire Administration – 2495 Hamilton Road
11. Troup County Senior Center – 140 Ragland Street
12. Troup County Connects – 144 Sam Walker Dr.
13. Troup County Recreation Center – 1220 LaFayette Parkway
14. First Tee – 1220 LaFayette Parkway
15. Shuford & Harris Fields Concession Stand – Ragland Street
16. William Griggs Rec. Center and Pool – 716 Glenn Robertson Dr.
17. Gray Hill Community Center – 3600 Bartley Road
18. Soccer Complex – 299 Fort Drive
19. Hogansville Senior Center – 304 Church Street – Hogansville, GA
20. Hogansville Parks & Rec. – 304 Church Street – Hogansville, GA
21. West Point Senior Center – 114 O.G. Skinner Drive – West Point, GA
22. West Point Parks & Rec. – US Highway 29 & 12th Street
23. Oakfuskee – 300 King Fisher Lane
24. Extension (Agricultural) Center – 2168 Pegasus Parkway
25. Whitesville Road Soccer Complex Gym – 1700 Whitesville Road
26. Former Bus Barn at Whitesville Rd Soccer Complex – 1700 Whitesville Rd

Locations may be added or removed at anytime.

