

Addendum #1

LaGrange Active Life Center

LED Pickleball Lighting System (+2 Existing Courts) - RFP (10/18/2024)

140 Ragland Street, LaGrange, Ga 30240

As discussed at the Mandatory Pre-Bid Meeting held on Thursday (October 31) at the Project Site, the following list of information and/or clarification shall be included in the RFP Scope of Work for this project:

- Court Lighting Level = Minimum 30FC Average, required. However, Troup County will also evaluate the overall LED lighting distribution over the entire court area. Please minimize the range from bright spots to dark/dim spots on the court area, please provide a relatively even distribution of light over the entire court area.
- Submit a photometric design layout (with the associated photometric design data/information) for review and approval, which demonstrates the minimum 30FC average and the overall lighting distribution levels.
- Submit a photometric design layout based on a total of two (2) 25' tall poles (Bronze in Color), centered on the courts, with a total of four (4) LED lights (Bronze in Color). Submit product information for review and approval.
- NO Bid Bonds, NO Payment Bonds, and NO Performance Bonds are required for this RFP, if the contract proposal is less than \$100,000.00.
- Provide and install the "all-weather" electrical service for the project located near the "existing security site lighting pole", as discussed. The electrical service shall include a galvanized metal frame (galvanized metal poles & galvanized metal unistrut channel), meter base, disconnect, and 100 Amp panel.
- Provide and install a timer switch with automatic cut-off at a specific time and/or timed delay, submit product information for review and approval.

- Troup County (City of LaGrange) will provide the necessary/required electrical power supply, at the “existing security site lighting pole” location, as discussed. Please submit the necessary/required electrical power supply on the **Proposal Form (Addendum #1)**, attached.
- Please submit the estimated lead time for material(s) on the **Proposal Form (Addendum #1)**, attached.

PROPOSAL FORM (ADDENDUM #1)

LaGrange Active Life Center

LED Pickleball Lighting System (+2 Existing Courts) - RFP (10/18/2024)

140 Ragland Street, LaGrange, Ga 30240

INVITED BIDDERS:

Having carefully examined the Request for Proposal (RFP) entitled “**LaGrange Active Life Center – LED Pickleball Lighting System (+2 Existing Courts) - RFP (10/18/2024)**” and Addendum No. _____ as well as the premises and conditions affecting the work, the undersigned proposes to furnish all services, labor, equipment, and materials called for by them for the entire scope of work included in the LED Pickleball Lighting System Proposal in accordance with said document for the **TOTAL SUM OF:**

_____ DOLLARS (\$ _____)

Necessary/Required Electrical Power Supply (by City of LaGrange): _____

Estimate Lead Time for Material(s): _____

Proposal to include a total of two (2) 25' tall poles (Bronze in Color), centered on the courts, with a total of four (4) LED lights (Bronze in Color).

The undersigned agrees that this proposal may not be revoked, or withdrawn for a period of sixty (60) days from and including the date of the Bid Opening.

The undersigned agrees to execute a contract (AIA Document A101) no later than ten (10) days from and including date of notification of acceptance of this proposal in writing, by mail, email, telegraph, facsimile transmission, or delivery.

The undersigned agrees to commence actual physical work on the site with an adequate force and equipment within thirty (30) days from and including a date to be specified in written order of the Owner and be substantially complete in ninety (90) consecutive calendar days.

Respectfully submitted,

Name: _____

Address: _____

By: _____

Title: _____

The full names and addresses of persons and firms interested in the forgoing bids as principals are as follows:

Legal Name of Bidder: _____