



March 3, 2025
RFI response #1

Project Name:
Troup Co Court Room 3C

Architect:
2WR+ Partners, an urban-gro Company

Architect's Project No:
24-01920

The Work identified in the following RFI Response is issued in accordance with the Construction Documents and included in the Bid Sum.

General: N/A

RFI responses:

1. Keynote 17 on A1.2 calls out "fabric wrapped panel system provided and installed by vendor." On sheet A10.1 these areas are designated "FWP-1" which states "provided and installed by others". Please clarify if this work is by the GC or not?

Response: The fabric wrapped acoustical wall panels will be provided and installed by Vendor.

2. Door #3621 is called out to be 3' 0" x 8' 10" but Marshfield does not make a 8' 10" STC 47 rated wood door. Please advise.

Response: Contact AMBICO LTD for door manufacturing, to match existing.

3. On A10.1 keynote "C" TV's are designated as CFCL, please provide a size and/or basis of design if we are to furnish them. On sheet E2.0, it states the owner's AV vendors will install the TV monitors. Please clarify.

Response: TVs are to be provided by the owner and installed by the contractor. GC to provide rough in and conduit boxes.

4. It calls for a card reader on some of the doors. It says to match existing. Can you provide what type and model number.

Response: Card readers will be handled the same way as the A/V, the GC shall install the rough in boxes/conduits/chases/prep as marked on the plans, but the Other Vendor will provide and install the hardware/software for the card reader system.

Drawings: N/A



Attachments: N/A

Specifications: N/A

End of RFI response

Issued By:

Sara Flora, Associate Director of Operations
2WR+ Partners, an urban-gro Company