

ADDENDA 1
RESTROOM REOVATIONS
AT
THE ACTIVE LIFE CENTER
140 RAGLAND STREET
LAGRANGE, GA 30241

The number indicated is a question about that item number of the request for bids.

6. Calls for replacing the glass windows in the men's restroom- You aren't thinking of replacing the entire window frame, sash and glass, are you? I would think replace the glass only. What are you wanting to replace it with? Opaque like it was?

Just the glass... and yes it should be opaque.

7. Where it calls for expanding the size of the handicapped stall in the women's restroom, are you meaning in depth only as changing the width would involve changing all the others. See attached drawing to make sure this is what you are looking for. Note the larger size space for the women's restroom.

Yes. The expansion will be in depth only.

14. Replace cabinets. Do you want the vanities to be built like the ones you have? See attached drawing. Existing has two doors with storage behind and a knee-space beside it. If it is to be built like this then you would have a cabinet box and doors. I would need to know what you want that built out of. If we are only doing a slanted front all the way across, then it would not be any cabinet boxes or doors. On the vanity top we will price Corian with an integrated sink bowl of the same material.

No. We are not interested in any storage, but would like a double faucet size trough sink. Must meet ADA requirements. Please provide spec sheet for what you are quoting.

15. Do you want to spec the automatic faucets and toilet flushing units? I would assume Zurn or Sloan as a manufacturer.

Zurn or Sloan are fine. Please provide spec sheet for what you are quoting.

19. Battery powered?

Prefer electrical. Please provide spec sheet for what you are quoting.

23. Are the recessed trash receptacle and dispenser combos recessed into the wall? Any spec on these?

No. Must be stainless. Please provide spec sheet for what you are quoting.

26. Do you have a spec on this coating?

No. Please provide spec sheet for what you are quoting.