

ADDENDUM 2  
CALLAWAY STADIUM  
INFILLED SYNTHETIC TURF PROJECT

1. The specs call for 3/8" stitch gauge with the turf. Can the specs be amended to reflect 3/8" or 1/2"?

*Only 3/8" stitch gauge will be accepted.*

**PLEASE INCLUDE AN ADD ALTERNATE TO YOUR BID TO ADD MARKING THE TURF FOR COLLEGIATE LACROSSE. THESE MARKINGS SHOULD BE IN A STANDARD COLOR THAT IS NOT ALREADY BEING USED FOR FOOTBALL OR SOCCER.**